



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pln:- 721101

Memo no.:IND/WB/FES/20192020/79158

Date: 02-12-2023

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: THE RENAISSANCE INTERNATIONAL SCHOOL,BLOCK 1,2(UNIVERSAL TRIBAL EDUCATIONAL TRUST) AND KHARGAPUR TRIBAL PRIMARY TEACHER'S TRAINING INSTITUTE,BLOCK3 (KANGSABATI DEVELOPMENT EMPLOYMENT AND SERVICE)
MOUZA - HAJICHAK AND MATKATPUR,J.L. NO. - 203 AND 204, KHATIAN NO. - 157, 156, 1023, PLOT NO-1,2,3, 4,149,150,165,166,295,296, VILL AND PO - MATKATPUR, PS-KHARAGPUR LOCAL,DIST-PASCHIM MEDINIPUR,721305

Sub: Renewal of Fire Safety Certificate of an existing construction of G+III storied Educational Building comprising 3 nos. Block (i.e Block-1, Block- 2 & Block-3) in the name & style "THE RENAISSANCE INTERNATIONAL SCHOOL" at Mouza- Matkatpur, J.L.No.- 203, Plot No.-149,150,165(P),166(P),295,296 and Mouza- Hazichack, J.L.No.- 204, Plot No.- 1(P),2(P),3&4, P.S.-Kharagpur Local, Dist-Paschim Medinipur,721305.

This is in reference to your application no. 0125191231500158 dated 31-10-2023 regarding the Renewal of Fire Safety Certificate of an existing construction of G+III storied Educational Building comprising 3 nos. Block (i.e Block-1, Block- 2 & Block-3) in the name & style "THE RENAISSANCE INTERNATIONAL SCHOOL" at Mouza- Matkatpur, J.L.No.- 203, Plot No.-149,150,165(P),166(P),295,296 and Mouza- Hazichack, J.L.No.- 204, Plot No.- 1(P),2(P),3&4, P.S.-Kharagpur Local, Dist-Paschim Medinipur,721305.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Conditional RFSC allow subject to comply the conditions with in Three Months and to be informed this end by written for regularization this certificate.

CONDITIONS :-

i) Over head water reservoir will be interconnected with under ground water reservoir by using riser and pump.

The authenticity of this document can be verified by accessing the URL www.district.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191231500158.


SECRET
The Renaissance International School
At. P.O.- Matkatpur P.S. - Kharagpur (L)
Dist. - Paschim Medinipur Pin-721305, W.B.


The Renaissance International School
At. P.O.- Matkatpur, P.S. - Kharagpur (L)
Dist. - Paschim Medinipur, Pin-721305, W.B.

ii) Stand by pump will be provided having capacity as same as main pump with auto driven facilities.

Except the above the General Recommendations are as Follows:-

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
4. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the building.
6. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
7. The employees and security staff shall be conversant with installed fire fighting equipments of the buildings and to operate in the event of fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
9. Transformer and switch gear shall be protected with automatic CO2 or DCP Fire extinguishers confirming I.S. specifications.
10. A trained Fireman shall be maintained round the clock for fire safety of the building.
11. First Aid fire fighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
13. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
15. Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of


Secretary
The Resurgence International School
Kharagpur (W.B.)
Dist - Paschim Medinipur Pin-721305, W.B.


Principal
The Resurgence International School
Kharagpur (W.B.)
Dist - Paschim Medinipur Pin-721305, W.B.

above mentioned system.

16. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
17. The Renewal of Fire Safety Certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.
18. This certificate is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.


Signature valid

Digitally Signed
Name: Barn Kumar Choudhury
Date: 02-Dec-2023 10:02
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services



Secretary
The Renaissance International School
At.+P.O.- Matkatpur P.S - Kharagpur (L)
Dist.- Paschim Medinipur Pin-721305, WB



Principal
The Renaissance International School
At.+P.O.- Matkatpur, P.S.- Kharagpur (L)
Dist.- Paschim Medinipur, Pin-721305, W.B.